# AstroCel® III 4000

## High Efficiency Particulate Air Filters

- E12, H13 and H14 according to EN1822:2009
- 4000 m³/h air volume saves space
- · Low energy consumption




AstroCel III is classified E12, H13 or H14according to EN1822:2009. The filter displays excellent efficiency on fine particulate matter and is designed for use in high air volume applications upto 4000 m³/h.

Due to its high capacity the filter offers several benefits in new installations, fewer filters are required to handle the same volume of air compared to HEPA filters of the same size with a lower capacity.

As a result, less installation space is required and installation time is significantly reduced. In existing installations, the filter's high media area ensures a low pressure drop which reduces energy costs.

## **Resistance vs Face Velocity**



## AstroCel®III 4000

An AstroCel III 4000 can be ordered using the following Component Code Definition System. Use the table to specify a product suitable to your application requirements.

#### **Selection Table**

Item	Component	Component Code Definition			
Α	Type of Filter	A39 = AstroCell III			
В	Media	A = Waterproof Glass Fibre (E12/H13) E = Waterproof Glass Fibre (H14)			
С	Cell Sides	05 = Sendzimir zinc coated steel (4000) 07 = Stainless steel 304 (4000)			
D	Separators	C = Thermoplastic			
Е	Bond	9 = Polyurethane Cold Cured Resin P = No gasket			
F	Gasket	S = polyurethane foam, half round profile, one piece T = 8 mm, flat profile 0 = No gasket			
G	Gasket Location	2 = One face			
Н	Acceptance Level	<b>G = E12 Min. 99.5% @ MPPS acc. to EN1822</b> H = H13 Min. 99.95% @ MPPS acc. to EN1822 R = H14 Min. 99.995% @ MPPS acc. to EN1822			
I	Faceguard Location	O = No faceguard			
K	Options	H - Handle, one side			

For 3400 MDF and NG execution consult refer to seperate brochure

Bold typeface: standard execution

#### **How to Order**

Below a typical example of how to order a standard AstroCel III 4000 filter using the Component Code Definition System.

Item	Α	В	С	D	Е	F	G	Н	I,	K
Component Definition	A39	Α	05	С	9	S	2	G	0	Н

#### **Initial resistance Table**

	Nominal airflow (m³/h)	Initial resistance (Pa)*
E12	4000	250
H13	4000	285
H14	4000	400

<sup>\*</sup> At nominal airflow m3/h

## **Standard Sizes and Ratings**

	n mm gasket	Nominal airflow		
Н	W	D	m³/h	
595	287	292	1385	
610	305	292	1500	
595	595	292	3800	
610	610	292	4000	

#### Notes:

- 1) Final resistance 750 Pa.
- 2) Temperature limit 70°C.

## International AAF Offices:

Emmen (NL), Glika Nera (GR), Brussels (B), Cramlington (GB), Oberhausen (D), Dubai (UAE), Helsinki (Fin), Istanbul (TR), Lisbon (P), Louisville, Ky (USA), Madrid (E), Mexico (Mex), Mozzate-Co (I), Paris (F), Bangalore (IND), Riyadh (KSA), Shah Alam (Mal),

Suzhou, Shenzhen (PRC), Singapore, Taiwan, Wr. Neudorf (A)

## AAF Agents:

Johannesburg (RSA)

Efficiency

E12

H13

H14

Efficiency EN1822 @ MPPS

99.5%

99.95%

99.995%

AAF-International B.V.

P.O. Box 60 7800 AB Emmen The Netherlands Tel: +31 591 686 911 Fax: +31 591 686 936 www.aafeurope.com



AAF has a policy of continuous product research and improvement and reserves the right to change design and specifications without notice.

RA-10-129-IN-1012 © 2012 AAF International